



Product Service


CERTIFICATE

No. Z2 099237 0010 Rev. 04

Holder of Certificate: **Jiangsu Eco Green Energy Co., Ltd**

No. 66 Shuangyun Road, Zixing Village, Xingdong Subdistrict,
Tongzhou District
226300 Nantong, Jiangsu
PEOPLE'S REPUBLIC OF CHINA

Certification Mark:



Product: **Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**
Mono-Crystalline Silicon Photovoltaic Module

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 704061830405-04

Valid until: 2026-06-06

Date, 2021-06-23

(Zhulin Zhang)

CERTIFICATE

No. Z2 099237 0010 Rev. 04

Model(s):

EGE-xxxM-72, xxx=335 to 400, in step of 5
 EGE-xxxM-60, xxx=280 to 335, in step of 5
 EGE-xxxM-54, xxx=255 to 300, in step of 5
 EGE-xxxM-48, xxx=225 to 265, in step of 5
 EGE-xxxM-36, xxx=10 to 200, in step of 5
 EGE-xxxW-144M(M6), xxx=420 to 450, in step of 5
 EGE-xxxW-132M(M6), xxx=390 to 415, in step of 5
 EGE-xxxW-120M(M6), xxx=350 to 375, in step of 5
 EGE-xxxW-144M(G1), xxx=390 to 415, in step of 5
 EGE-xxxW-132M(G1), xxx=360 to 380, in step of 5
 EGE-xxxW-120M(G1), xxx=325 to 345, in step of 5
 EGE-xxxW-144M(M10), xxx=530 to 555, in step of 5
 EGE-xxxW-132M(M10), xxx=485 to 510, in step of 5
 EGE-xxxW-120M(M10), xxx=440 to 465, in step of 5
 EGE-xxxW-108M(M10), xxx=395 to 420, in step of 5
 EGE-xxxW-120M(M12), xxx=575 to 605, in step of 5
 EGE-xxxW-108M(M12), xxx=520 to 545, in step of 5
 xxx is standing for rated output power at STC

Parameters:

Construction:	Framed, with Junction box, Cable and Connectors.
Safety Class :	Class II
Maximum System Voltage:	1500 V DC
Fire Safety Class:	Class C according to UL790.
Test Laboratory:	Yangzhou Opto-Electrical Products Testing Institute, No. 10 West Kaifa Road, Yangzhou, 225009 Jiangsu, P. R. China.

Tested according to:

IEC 61215-1:2016
 IEC 61215-1-1:2016
 IEC 61215-2:2016
 IEC 61730-1:2016
 IEC 61730-2:2016
 EN 61215-1:2016
 EN 61215-1-1:2016
 EN 61215-2:2017
 EN IEC 61730-1:2018
 EN IEC 61730-1:2018/AC:2018-06
 EN IEC 61730-2:2018
 EN IEC 61730-2:2018/AC:2018-06